


# Phigenics Validation Test (THAB) Analytical Report

Method Used: Total Heterotrophic Aerobic Bacteria

PVT Sample Information	
PASL #:	10000
Date Inoculated in Field:	2013/01/01
Date of Analysis:	2013/01/03

Total Heterotrophic Aerobic Bacteria	
Total Heterotrophic Aerobic Bacteria	*** Score
	<u>10<sup>3</sup></u> CFU/ml



Growth media for viable total heterotrophic aerobic bacteria.

Location Identification		
<b>Sink #1 Hot</b>		
Acid Treated?	Date of Testing	Circle One
<input checked="" type="radio"/> N or Y	<u>01/01/13</u> MM / DD / YY	<input checked="" type="radio"/> Potable
Signature of Collector		
<u>Joe Smith</u>		

Notes: Dipslide received intact.

Analyst Signature *Selvy Leonidas*  
Date 1/3/2013

Reviewer Signature *William J. M. Coz*  
Date 1/3/2013

**Disclaimer:** Results from the PVT, or from any other analytical protocol for that matter, do not necessarily provide enough evidence to ensure that hazards from pathogenic microorganisms have been eliminated or controlled nor that risk of harm from such hazards has been reduced. Results from the PVT should only be interpreted within the context of properly designed and implemented water management plans. No guarantee regarding results is expressed or implied. THE PVT AND THE RESULTS IT PRODUCES ARE PROVIDED ON AN "AS IS" BASIS. YOU ASSUME TOTAL RESPONSIBILITY AND RISK FOR YOUR USE OF THE PVT AND PHIGENICS IS NEITHER RESPONSIBLE NOR LIABLE FOR ANY DAMAGES ARISING OUT OF YOUR USE OF THE PVT.