



PHIGENICS ANALYTICAL SERVICES LABORATORY
 35701 West Ave, Suite 100, Warrenville, IL 60555
 Telephone: 844-850-4087 Fax: 630-717-8528 Website: www.phigenics.com

A CDC ELITE Certified Laboratory

Facility Tested: Test Site #1
 Date of Testing: 2019/01/01
 Contact Email: jsmith@email.com

Validation Criteria:
Potable Water - typically in well managed systems, the total viable heterotrophic aerobic bacterial concentration should be less than or equal to 10³CFU/ml. Per the OSHA Legionella Technical Manual, the viable Legionella concentration should be less than 10 CFU/ml unless the water system serves immunocompromised or higher risk users which require a more stringent level of Legionella control (less than 1 CFU/ml).
Utility Water (such as cooling water) - typically in well managed systems, the total viable heterotrophic aerobic bacterial concentration should be less than or equal to 10⁴ CFU/ml. For closed recirculating utility water, the total viable heterotrophic aerobic bacterial concentration should be less than or equal to 10² CFU/ml. Per the OSHA Legionella Technical Manual, the viable Legionella concentration should be less than 10 CFU/ml.
 - The facility **Water Management Team** should review all options for Validation Criteria and choose its specific criteria based on the specific systems and users.

Phigenics Validation Test (PVT with ISO) Report Summary

Method Used: TimeZero Method and ISO 11731 Spread Plate Method

Legionella Caution		Indicates Legionella was detected.
THAB Caution		Indicates total heterotrophic bacteria count exceeds the validation criteria (10 ³ for potable, 10 ⁴ for utility, 10 ³ for closed recirculating utility).
NO Concern		Indicates results are better than the validation criteria.
	ND	Indicates Legionella was not detected.
	P	Indicates results are pending.

PASL Number	Date Inoculated	Date Analyzed	Collector	Location Identification	Category (Potable/Utility)	PVT (at t=0)			ISO 11731 Spread Plate			
						Total Bacteria	Lpn S1	Lpn S2-14	Legionella Spp	Lpn S1	Lpn S2-14	Legionella Spp
						CFU/mL						
10000	2019/01/01	2019/01/11	J. Smith	Sink #1 Hot	Potable	10 ³	70	ND	ND	62	<1	<1
10001	2019/01/01	2019/01/11	J. Smith	Sink #2 Cold	Potable	10 ⁵	ND	ND	ND	<1	<1	<1
10002	2019/01/01	2019/01/11	J. Smith	Sink #3 Hot	Potable	10 ²	ND	ND	ND	<1	<1	<1
10003	2019/01/01	2019/01/11	J. Smith	Sink #4 Cold	Potable	<100	ND	ND	ND	<1	<1	<1
10004	2019/01/01	2019/01/11	J. Smith	Shower #1 Hot	Potable	10 ³	30	ND	ND	28	<1	<1
10005	2019/01/01	2019/01/11	J. Smith	Shower #2 Cold	Potable	10 ²	ND	ND	ND	<1	<1	<1
10006	2019/01/01	2019/01/11	J. Smith	Shower #3 Hot	Potable	10 ⁴	ND	ND	ND	<1	<1	<1
10007	2019/01/01	2019/01/11	J. Smith	Shower #4 Cold	Potable	<100	ND	ND	ND	<1	<1	<1
10008	2019/01/01	2019/01/11	J. Smith	Ice Machine #1	Potable	<100	ND	ND	ND	<1	<1	<1
10009	2019/01/01	2019/01/11	J. Smith	Ice Machine #2	Potable	<100	ND	ND	ND	<1	<1	<1
10010	2019/01/01	2019/01/11	J. Smith	Drinking Fountain #1	Potable	<100	ND	ND	ND	<1	<1	<1
10011	2019/01/01	2019/01/11	J. Smith	Drinking Fountain #2	Potable	10 ²	20	ND	ND	<1	<1	<1
10012	2019/01/01	2019/01/11	J. Smith	Misting System	Potable	10 ⁶	ND	ND	ND	<1	<1	<1
10013	2019/01/01	2019/01/11	J. Smith	Cooling Tower #1	Utility	10 ⁴	50	ND	ND	10	<10	<10
10014	2019/01/01	2019/01/11	J. Smith	Cooling Tower #2	Utility	10 ⁷	ND	ND	ND	<10	<10	<10
10015	2019/01/01	2019/01/11	J. Smith	Cooling Tower #3	Utility	10 ⁵	30	ND	ND	50	<10	<10
10016	2019/01/01	2019/01/11	J. Smith	Evaporative Cooler #4	Utility	10 ⁴	60	ND	ND	70	<10	<10

Disclaimer: Results from the PVT, or from any other analytical protocol for that matter, do not necessarily provide enough evidence to ensure that hazards from pathogenic microorganisms have been eliminated or controlled nor that risk of harm from such hazards has been reduced. Results from the PVT should only be interpreted within the context of properly designed and implemented water management plans. No guarantee regarding results is expressed or implied. THE PVT AND THE RESULTS IT PRODUCES ARE PROVIDED ON AN "AS IS" BASIS. YOU ASSUME TOTAL RESPONSIBILITY AND RISK FOR YOUR USE OF THE PVT AND PHIGENICS IS NEITHER RESPONSIBLE NOR LIABLE FOR ANY DAMAGES ARISING OUT OF YOUR USE OF THE PVT.